Fieldbus System e UL-compliant (Output device for driving 5-port solenoid valves) RoHS Space-saving IO-Link compatible **IP67** installation * For units with a D-sub connector/RJ45 connector, and when connected to S0700 manifolds, it is IP40. Drives up to 32 solenoids Compact Approx. Daisy-chain wiring Actual size Dmm communication Excludes the units compatible with IO-Link 62 ß **Compatible Protocols** Fieldbusses & Industrial Ethernet **Safety Communication** CC-Link profo Safety over Device/\et EtherNet/IP BUS EtherCAT. New CC-Línk IE TSN **OID**-Link Ether CAT. POWERLINK

CAT.E02-25E

Compliant with functional safety standards **D**.5 (PROFIsafe, Safety over EtherCAT[®] compatible)

Product certification obtained by a third party

Safety output for valve control



Narrow Space saving installation






M12 communication connector x 1 (Same for the solenoid valve power supply wiring) **IO-Link** D-sub communication connector






Daisy-chain wiring communication is possible.*1

A branch connector is not necessary/Reduced wiring space *1 Excludes the units compatible with IO-Link




Wiring and piping from the same direction is possible. (for side ported)



An external terminating resistor is not necessary.

(Only available for M12 PROFIBUS DP, CC-Link communication connectors)

ON/OFF switching is possible with an internal terminating resistor. An external terminating resistor is not necessary.



SMC

<u> </u>	1	DeviceNet	CC-Link	<u>prof</u> o® Met	EtherNet/IP	Ether CAT	ethernet POWERLINK	@ IO -Link	New CC-Línk IE TSN	PROFisale	Safety over EtherCAT.
Communication connector D-sub RJ45						•			•		•

Product Specification Variations

Fieldbusses & Industrial Ethernet

Applicable Valve Series and Compatible Protocols

ppopp [®] DeviceNet CC-Link ppopp [®] P	EtherNet/IP Eth		RLINK	😢 IO-Lir	ık CC-Línk IETSI	v
Applicable valve		Flow rate charac (4/2 \rightarrow 5/3		Max. number	Power consumption [W]	Applicable cylinder size
	C [dm³/(s·bar)]	b	of solenoids	[vv]	cylinder size	
₽ ⁶⁷ *1 € ୯ ६ ୯୯	SY3000	1.6	0.19		0.35 (Standard)	ø50
		3.6	0.17	32	0.1 (With power-	ø63
c AL us	SY7000	5.9	0.20		saving circuit)	ø80
IP67 *1,*2	JSY1000	0.91	0.48		0.2 (With power-saving circuit)	ø40
(6) (6) (6) (6) (6) (6) (6) (6)	JSY3000	2.77	0.27	32	0.4 (Standard) 0.1 (With power- saving circuit)	ø50
- 12 gamma	JSY5000	6.59	0.22			ø80
IP40 CE LK	S0700 *3	0.37	0.39	32	0.35	ø25
	01/1000*2	1.1	0.35	32	0.6	ø40
		2.4	0.18			ø63
c Aus	SV3000*3	4.3	0.21			ø80
IP67 *1	VQC1000	1.0	0.30		0.4 (Standard)	ø40
CE K	VQC2000	3.2	0.30			ø63
	VQC4000	7.3	0.38	24	0.95 (Standard)	ø160
ist in	VQC5000	17	0.31		0.4 (Low-wattage type)	ø180
Applicable vacuum unit		Nozzle diamo [mm]	eter	Max. number of solenoids	Power consumption [W]	Max. vacuum pressur [kPa]
IP40 MARKA		0.7				
CE	ZK2⊡A	1.0		16	0.4	-91
		1.2				
NO.		1.5				

Safety Communication

The use of validated products may be required for valve manifolds used in the safety-related parts of equipment which is compliant with safety standard ISO 13849. For validated products, please contact your SMC sales representative.

Safety over EtherCAT.

Applicable valve	Flow rate characteristics (4/2 \rightarrow 5/3)		Max. number	Power consumption [W]	Applicable cylinder size	
	C [dm³/(s·bar)]	b		[44]	Cymuel Size	
P67 C E 监	SY3000	1.6	0.19		0.35 (Standard) 0.1 (With power- saving circuit)	ø50
		3.6	0.17	32		ø63
c Al us	SY7000	5.9	0.20			ø80
IP67 *2	JSY1000	0.91	0.48	32	0.2 (With power-saving circuit)	ø40
	JSY3000	2.77	0.27		0.4 (Standard) 0.1 (With power- saving circuit)	ø50
	JSY5000	6.59	0.22			ø80
IP67	VQC1000	1.0	0.30		0.4 (Standard)	ø40
and the second second	VQC2000	3.2	0.30	24	0.4 (Standard)	ø63
CE K	VQC4000	7.3	0.38		0.95 (Standard)	ø160
1. A. C.	VQC5000	17	0.31		0.4 (Low-wattage type)	ø180

*1 Units with a D-sub communication connector/RJ45 communication connector are IP40.

*2 The JSY1000 is IP40.

*3 IO-Link compatible and CC-Link IE TSN compatible SI units do not have set up a manifold part number.




IO-Link compatible

Integratable with various existing networks


IO-Link devices can be easily connected to various networks via the IO-Link master, which acts as a gateway between IO-Link communication and various Fieldbusses.

Solenoid valves can be connected for communication without relying upon a Fieldbus or PLC.



SMC

IO-Link compatible




Equipped with a solenoid valve output operation count function

The number of valve operation instructions is counted for each output of the solenoid valve.

Set the count threshold value to be used as a guide for maintenance according to the operating conditions of the cylinder connected to the solenoid value.

Once the threshold value is reached, notification of this fact will take place automatically.


This enables periodic maintenance to be performed before any unexpected cylinder failures occur.



Supports safety communication

The safety communication protocol is a communication protocol that transmits safety-related data over a communication network and are compatible for use up to safety standard ISO 13849-1 PL e and IEC 61508/IEC 62061 SIL 3.

Examples of PROFIsafe and PROFINET compatible products.



Compliant with safety standards

The purpose is to facilitate the safe design (compliant with ISO/IEC standards) of the customers devices and equipment, and the products have been certified by a third party organization (such as TÜV Rheinland) to be usable up to the levels of the following standards.



www.tuv.com ID 060000000

IEC 61508/IEC 62061 SIL 3 ISO 13849 PL e/Cat. 3

Safety Output

The product has a safety switch inside, and by turning OFF the safety switch via a command from the PLC, the voltage supplied to the valve is turned OFF and the product enters a safe state. The safety switch inside the product has redundancy and constantly undergoes diagnosis. The safety switch is turned OFF if an error is detected.




A safety integrity level as defined by international standard IEC 61508/62061

There are 4 levels of safety, with the lowest being SIL 1 and the highest being SIL 4.

· PL (Performance Level)

A scale used to define the capability of safety-related parts to perform a safety function as defined by international standard ISO 13849

There are 5 levels of safety function, with the lowest being PL a and the highest being PL e.



ASafety Definition


The safe state of this product is a condition in which the safety output described above is turned OFF to shut off the supply of power to the valve manifold. This product does not cover valve manifolds that are being used in connection with this product or the safety function and safe state of electric/air equipment that includes a peripheral circuit.



Reduced wiring, Space saving


For safety communication compliant SI unit (EX260-F

- A separate safety output unit is not required. (Space saving)
- There is no need for wiring between the safety output unit and the SI unit. (Reduced wiring)



When a separate safety output unit is installed (Conventional connection example)

- A separate safety output unit is required. (Increased installation space)
- Increased wiring is required for connection with another unit. (Increased wiring)



Safety of the machine or system

The manufacturer of the machine/system and its user are responsible for the safety of the machine/system. Use of this product requires machine/ system safety concepts which are in accordance with the corresponding directives and standards, safety function validation, and hazard and risk analysis. Target SILs (IEC 61508/62061 compliance) and performance levels/categories (ISO 13849 compliance) are determined based on the risk analysis. For more information, refer to the "Safety of the machine or system" section in the operation manual.

CONTENTS

Fieldbus System (Output device for driving 5-port solenoid valves) EX260 Series




How to Order SI Unitsp. 9)
Specifications ······p. 10)
Dimensions ······p. 12	2
Parts Description ······p. 14	ł
L ED Indicator ······p. 15	;


Accessories

Communication Cablep. 17
2 Field-wireable Communication Connector p. 23
3 Power Supply Cable (For SI unit)p. 24
Power Supply Cable (For SI unit/For power block) ···· p. 25
Seal Cap (10 pcs.) p. 25
Output Blockp. 26
Power Block
Connector for Output Block Wiring p. 27
End Plate ······p. 27
Bracket Plate/DIN Rail Mounting Bracketp. 27

Made to Order

	SI Unit ······	- 28
	Communication Cable	
	•	
	Power Supply Cable	5.30
Sp	pecific Product Precautions	o. 31






Fieldbus SystemFor OutputC E UK
C E CAEX260 SeriesRoHS

Compact design	Compact design for space saving
Number of outputs	32/16 digital output
Output polarity	Negative common (PNP)/Positive common (NPN)
Enclosure	IP67 (For units with a D-sub connector/RJ45 connector, and when connected with S0700 manifolds, it is IP40.)
Internal terminating resistor	ON/OFF switching is possible with an internal terminating resistor for communication. (Only for units compatible with M12 PROFIBUS DP, CC-Link communication connectors)

Applicable Manifold



ZK2□A


Communication protocol -

How to Order SI Units

EX260-SPR1

	Brotocol		Output palarity	Communication connector	Manifold symbol	Applicable manifold / /acume weit
Symbol	Protocol	Number of outputs	Output polarity	Communication connector	Manifold symbol	Applicable manifold/Vacuum unit
DN1		32	Source/PNP (Negative common)	-	QAN	
DN2	DeviceNet®		Sink/NPN (Positive common)	M12	QA	
DN3		16	Source/PNP (Negative common)	-	QBN	
DN4			Sink/NPN (Positive common)		QB	
PR1		32	Source/PNP (Negative common)	4	NAN	
PR2			Sink/NPN (Positive common)	M12	NA	
PR3		16	Source/PNP (Negative common)	4	NBN	
PR4	PROFIBUS DP		Sink/NPN (Positive common)		NB	
PR5		32	Source/PNP (Negative common)		NCN	
PR6			Sink/NPN (Positive common)	- D-sub ^{*1}	NC	
PR7		16	Source/PNP (Negative common)	D-Sub	NDN	
PR8			Sink/NPN (Positive common)		ND	
MJ1		32	Source/PNP (Negative common)		VAN	SY3000/5000/7000
MJ2	CC-Link	52	Sink/NPN (Positive common)	- M12	VA	JSY1000/3000/5000
MJ3	00-LIIK	16	Source/PNP (Negative common)		VBN	VQC1000/2000/4000/5000
MJ4			Sink/NPN (Positive common)		VB	S0700
EC1		32	Source/PNP (Negative common)	M12	DAN	SV1000/2000/3000 ZK2⊟A
EC2	Ethor CAT	32	Sink/NPN (Positive common)		DA	
EC3	EtherCAT	16	Source/PNP (Negative common)		DBN	
EC4			Sink/NPN (Positive common)		DB	
PN1		20	Source/PNP (Negative common)		FAN	
PN2	DDOEINET	32	Sink/NPN (Positive common)	M12	FA	
PN3	PROFINET	10	Source/PNP (Negative common)		FBN	
PN4		16	Sink/NPN (Positive common)	1	FB	
EN1		20	Source/PNP (Negative common)		EAN	
EN2		32	Sink/NPN (Positive common)		EA	
EN3	EtherNet/IP™	10	Source/PNP (Negative common)	M12	EBN	
EN4		16	Sink/NPN (Positive common)		EB	
PL1	Ethernet	32			GAN	
PL3	POWERLINK	16	Source/PNP (Negative common)	M12	GBN	
IL1	IO-Link	- 32	Source/PNP (Negative common)	M12	KAN	SY3000/5000/7000 JSY1000/3000/5000
CT1	CC-Link IE TSN	52	Courcer me (negative common)	RJ45	CAN	VQC1000/2000/4000/5000 ZK2⊟A

*1 If the communication connector specification is a D-sub or RJ45 connector, the enclosure rating is IP40.



EtherNet/IP[™] LAN cable connectable RJ45 communication connectors EtherNet/IP[™] Web server function compatible

* For "How to Order Manifold Assembly," refer to the Web Catalog of each valve.

Safety communication compliant SI unit

EX260-F PS1

Communication protocol -

	-						
Symbol	Protocol	Number of outputs	Output polarity	Communication connector	Manifold symbol	Applicable manifold	
PS1	PROFIsafe				FPN	SY3000/5000/7000	
SE1	Safety over EtherCAT®	32	Source/PNP (Negative common)	M12	DPN	JSY1000/3000/5000 VQC1000/2000/4000/5000	

* The use of validated products may be required for valve manifolds used in the safety-related parts of equipment which is compliant with safety standard ISO 13849. For validated products, please contact your SMC sales representative.



Specifications

All SI Units Common Specifications

Power supply	Power supply voltage	21.6 to 26.4 VDC*1				
for control	Internal current consumption	100 mA or less ^{*4}				
Power supply for output	Power supply voltage	22.8 to 26.4 VDC*5				
	Enclosure	IP67*2				
_	Operating temperature range	–10 to +50°C				
Environmental resistance	Operating humidity range	35 to 85% RH (No condensation)				
loolotanoo	Withstand voltage	500 VAC for 1 minute between terminals and housing				
	Insulation resistance	10 $\mbox{M}\Omega$ or more (500 VDC measured via megohmmeter) between terminals and housi				
Standards		CE/UKCA marking, UL (CSA) compliant				
Weight		200 g				
	Mounting screw	2 pcs.				
Accessories	Seal cap (for M12 connector socket)	EX9-AWTS (1 pc.)*3				

*1 The power supply voltage for the EX260-SDN is 11 to 25 VDC, for the EX260-SIL1 is 18 to 30 VDC, and for the EX260-FPS1/SCT1/FSE1 is 20.4 to 28.8 VDC.
*2 IP40 applies to EX260-SPR5/6/7/8, EX260-SCT1.
*3 Not provided for EX260-SPR5/6/7/8. The EX260-SCT1 is supplied with one dustproof cap for the RJ45 connector.

*4 The EX260-FPS1 is 200 mA or less, and the EX260-SCT1/FSE1 is 150 mA or less.

*5 The power supply for the EX260-SCT1/FPS1/FSE1 is 20.4 to 28.8 VDC. Check the specifications of the solenoid valve for the power supply details.

Ν	Nodel	EX260-SPR1/3	EX260-SPR2/4	EX260-SPR5/7	EX260-SPR6/8	EX260-SDN1/3	EX260-SDN2/4
	Protocol		PROFIE	Devic	DeviceNet®		
Applicable system	Version*1		DP	Volume 1 (Volume 3 (,		
	Configuration file*3		GSI) file		EDS	5 file
I/O occupation area (Inputs/Outputs)		SPR1: 0/32 SPR3: 0/16	SPR2: 0/32 SPR4: 0/16	SPR5: 0/32 SPR7: 0/16	SPR6: 0/32 SPR8: 0/16	SDN1: 0/32 SDN3: 0/16	SDN2: 0/32 SDN4: 0/16
Applicable	e function		-	_	QuickCo	QuickConnect™	
Communi	cation speed	9.6 k/19.2 k/	45.45 k/93.75 k/187.	7.5 k/500 k/1.5 M/3 M/6 M/12 Mbps 125 k/250 k/500 kbps			
Communication of	connector specification	M12 D-sub ^{*4}			M12		
Terminating	g resistor switch	Built-in No			ne		
	Output type	Source/PNP (Negative common)	Sink/NPN (Positive common)	Source/PNP (Negative common)	Sink/NPN (Positive common)	Source/PNP (Negative common)	Sink/NPN (Positive common)
Output	Number of outputs	SPR1: 32 points SPR3: 16 points	SPR2: 32 points SPR4: 16 points	SPR5: 32 points SPR7: 16 points	SPR6: 32 points SPR8: 16 points	SDN1: 32 points SDN3: 16 points	SDN2: 32 points SDN4: 16 points
Output	Load		Solenoid valve v	vith surge voltage sup	pressor 24 VDC, 1.5	W or less (SMC)	
	Supplied voltage			24 \	/DC		
	Supplied current	SPR1: Max. 2.0 A SPR3: Max. 1.0 A	SPR2: Max. 2.0 A SPR4: Max. 1.0 A	SPR5: Max. 2.0 A SPR7: Max. 1.0 A	SPR6: Max. 2.0 A SPR8: Max. 1.0 A	SDN1: Max. 2.0 A SDN3: Max. 1.0 A	SDN2: Max. 2.0 A SDN4: Max. 1.0 A

N	/lodel	EX260-SMJ1/3	EX260-SMJ2/4	EX260-SEC1/3	EX260-SEC2/4	EX260-SPN1/3	EX260-SPN2/4		
	Protocol	-CC-	Link	Ether	EtherCAT*2		NET*2		
Applicable system	Version*1	Ver.	1.10	Confor Test Rec		PROFINET S Versio	•		
	Configuration file*3	CSP	+ file	XML	file	GSE) file		
I/O occupation area (Inputs/Outputs)		SMJ1: 32/32 SMJ3: 32/32 (1 station, remote I/O stations)	SMJ2: 32/32 SMJ4: 32/32 (1 station, remote I/O stations)	SEC1: 0/32 SEC3: 0/16	SEC2: 0/32 SEC4: 0/16	SPN1: 0/32 SPN3: 0/16	SPN2: 0/32 SPN4: 0/16		
Applicable	e function		-	– FSU, MRP					
Communie	cation speed	156 k/625 k/2.5 M/5 M/10 Mbps) Mbps ^{*2}			
Communication of	connector specification	M12							
Terminating	g resistor switch	Bui	lt-in		None (No	t required)			
	Output type	Source/PNP (Negative common)	Sink/NPN (Positive common)	Source/PNP (Negative common)	Sink/NPN (Positive common)	Source/PNP (Negative common)	Sink/NPN (Positive common)		
	Number of outputs	SMJ1: 32 points SMJ3: 16 points	SMJ2: 32 points SMJ4: 16 points	SEC1: 32 points SEC3: 16 points	SEC2: 32 points SEC4: 16 points	SPN1: 32 points SPN3: 16 points	SPN2: 32 points SPN4: 16 points		
Output	Load	Solenoid valve v	vith surge voltage sup	opressor 24 VDC, 1.5	W or less (SMC)	Solenoid valve with surge voltage suppressor 24 VDC, 1.0 W or less (SMC)			
	Supplied voltage			24 \	/DC				
	Supplied current	SMJ1: Max. 2.0 A SMJ2: Max. 2.0 A SMJ3: Max. 1.0 A SMJ4: Max. 1.0 A		SEC1: Max. 2.0 A SEC3: Max. 1.0 A	SEC2: Max. 2.0 A SEC4: Max. 1.0 A	SPN1: Max. 2.0 A SPN3: Max. 1.0 A	SPN2: Max. 2.0 A SPN4: Max. 1.0 A		

*1 Please note that the version is subject to change.

*2 Use a CAT5 or higher communication cable for EtherCAT, PROFINET, Ethernet/IP™, and Ethernet POWERLINK.

*3 The configuration file can be downloaded from the SMC website: https://www.smcworld.com

*4 Enclosure is IP40 when the communication connector is D-sub.



Specifications

-							
Model		EX260-SEN1/3	EX260-SEN2/4	EX260-SPL1	EX260-SPL3	EX260-SIL1	EX260-SCT1
	Protocol	EtherNe	t/IP™*²	Ethernet POWERLINK		IO-Link	CC-Link IE TSN
Applicable system	Version*1	Volume 1 (E Volume 2 (E		EPSG DS 301 Version 1.2.0		V1.1	Class B ver. 2.0
	Configuration file*3	EDS file		XDD file		IODD file	CSP + file
I/O occupation area (Inputs/Outputs)		SEN1: 16/32 SEN3: 16/16	SEN2: 16/32 SEN4: 16/16	16/32	16/16	0/32 16/32 ^{*4}	32/32
Applicable	function	QuickConn	ect™, DLR	-	_	_	_
Communie	cation speed	10 M/100) Mbps ^{*2}	100 M	lbps*2	COM3/COM2*4	100 Mbps/1 Gbps*5
Communication of	connector specification	M12				RJ45	
Terminating	resistor switch	None (Not required)					
	Output type	Source/PNP (Negative common)	Sink/NPN (Positive common)	Source/PNP (Negative common)			
	Number of outputs	SEN1: 32 points SEN3: 16 points	SEN2: 32 points SEN4: 16 points	32 16 32			32
Output	Load				valve with surge voltage surg 4 VDC, 1.5 W or less (SMC) suppre		Solenoid valve with surge voltage suppressor 24 VDC, 0.95 W or less (SMC)
	Supplied voltage			24 \	/DC		
	Supplied current	SEN1: Max. 2.0 A SEN3: Max. 1.0 A	SEN2: Max. 2.0 A SEN4: Max. 1.0 A	Max. 2 A	Max. 1 A	Max. 2 A	Max. 1.3 A

*1 Please note that the version is subject to change.

*2 Use a CAT5 or higher communication cable for PROFINET, PROFIsafe, Ethernet/IP™, and Ethernet POWERLINK.

*3 The configuration file can be downloaded from the SMC website: https://www.smcworld.com

*4 A selection can be made using the setting switch.

*5 Use a CAT5e or higher communication cable for CC-Link IE TSN.

* In addition, it occupies input 4 bite/output 5 bite for safety.

Safety Communication Compliant SI Unit

Model		EX260-FPS1	EX260-FSE1	
	Protocol	PROFINET/ PROFIsafe ^{*2}	Safety over EtherCAT [®]	
Applicable system	Version ^{*1}	PROFINET Specification Version 2.3 PROFIsafe Specification Version 2.4	Conformance Test Record V.2.6.0	
	Configuration file*3	GSD file	ESI file	
I/O occupation area (Inputs/Outputs)		0/32*4		
Applicable	function	FSU, Shared Device, MRP	-	
Communio	cation speed	100 M	lbps*2	
Communication of	connector specification	M	12	
Terminating	resistor switch	None (Not required)		
	Output type	Source/PNP (Negative common)		
	Number of outputs	32		
Output	Load	Solenoid valve with surge voltage suppressor 24 VDC, 0.95 W or less (SMC)		
	Supplied voltage	24 VDC		
	Supplied current	nt Max. 1.3 A		

*1 Please note that the version is subject to change.

*2 Use a CAT5 or higher communication cable for PROFINET, PROFIsafe, Ethernet/IP™, Ethernet POWERLINK, and Safety over EtherCAT®.

*3 The configuration file can be downloaded from the SMC website: https://www.smcworld.com

 $\ast 4~$ In addition, it stores data for functional safety.


* A selection can be made using the setting switch.


Dimensions

M12 communication connector type (Fieldbus)


For PROFIBUS DP

For CC-Link







For DeviceNet®



M12 communication connector type

For IO-Link





D-sub communication connector type (EX260-SPR5/6/7/8)

21


20.6


78

16.4 9

For PROFIBUS DP

28.2







Dimensions

RJ45 communication connector type


For CC-Link IE TSN





Fieldbus System For Output **EX260** Series

Parts Description



The setting switch varies depending on the model.
 Refer to the operation manual for details.
 It can be downloaded via the SMC website: https://www.smcworld.com

<Connector> M12 communication connector type

Part no.	EX260-SPR□	EX260-SDN⊡	EX260-SMJ⊟	EX260-SEC EX260-SPN EX260-SEN EX260-SPL EX260-FPS1 EX260-FSE1
Communication protocol	PROFIBUS DP	DeviceNet [®]	CC-Link	EtherCAT PROFINET EtherNet/IP™ EtherNet POWERLINK PROFIsafe Safety over EtherCAT®
Communication connector (M12) BUS OUT	5 pins, socket, B code (SPEEDCON)	5 pins, socket, A code (SPEEDCON)	5 pins, socket, A code*1 (SPEEDCON)	4 pins, socket, D code (SPEEDCON)
Communication connector (M12) BUS IN	5 pins, plug, B code (SPEEDCON)	5 pins, plug, A code (SPEEDCON)	4 pins, plug, A code (SPEEDCON)	4 pins, socket, D code (SPEEDCON)
Ground terminal		Μ	3	
Power connector (M12)	5 pins, plug, A code (SPEEDCON)	4 pins, plug, A code (SPEEDCON)	5 pins, plug, B code (SPEEDCON)	5 pins ^{*2} , 4 pins ^{*3} , plug, A code (SPEEDCON)

<Connector> D-sub communication connector type

•

		Part no.	EX260-SPR5/-SPR6/-SPR7/-SPR8
•		Communication protocol	PROFIBUS DP
Ð		Ground terminal	M3
۱		Communication connector (D-sub) BUS IN/OUT	9 pins, socket
	Γ	Power connector (M12)	5 pins, plug, A code

*1 Recommended mating M12 4-pin plug part no.: PCA-1567717

*2 For EtherCAT, PROFINET, and Ethernet POWERLINK

*3 For EtherNet/IP™, PROFIsafe, and Safety over EtherCAT®

<Connector> RJ45 communication connector type


\bigcirc	Part no.	EX260-SCT1
	Protocol	CC-Link IE TSN
	Communication connector (PORT1)	BJ45 connector
	Communication connector (PORT2)	NJ45 CONNECTOR
	Power connector	5 pin Spring-loaded connector

<Connector>

SMC

		Part no.	EX260-SIL1
		Communication protocol	IO-Link
		Communication/ Power connector (M12)	5 pins, plug, ^{*1} A code (SPEEDCON)
	Ground term		M3
line, and the sol		*1 The communication line line, and the solenoid va are connected using the	alve power supply line


LED Indicator




SMC

Fieldbus System For Output **EX260** Series

LED Indicator











Communication Cable



EX9-AC 005 MJ-SSPS (With connector on both sides (Socket/Plug))

• Cable length (L)				
005	500 mm			
010	1000 mm			
020	2000 mm			
030	3000 mm			
050	5000 mm			
100	10000 mm			


Item		Specifications		
Cable O.D.		ø7.7 mm		
Conductor nominal Data pair		0.5 mm ² /AWG20		
cross section Drain		0.34 mm ² /AWG22		
Wire O.D. (Including insulator)		2.55 mm		
Min. bending radius (Fixed)		77 mm		



EX9-AC 005 MJ-SAPA (With angled connector on both sides (Socket/Plug))


• Cable length (L)			
005	500 mm		
010	1000 mm		
020	2000 mm		
030	3000 mm		
050	5000 mm		
100	10000 mm		

Item		Specifications
Cable O.D.		ø7.7 mm
Conductor nominal	Data pair	0.5 mm ² /AWG20
cross section Drain		0.34 mm ² /AWG22
Wire O.D. (Including insulator)		2.55 mm
Min. bending radius (Fixed)		77 mm



SMC

Accessories **EX260** Series




Communication Cable

EX9-AC 005 DN-SSPS (With connector on both sides (Socket/Plug))

• Cable length (L)				
005	500 mm			
010	1000 mm			
020	2000 mm			
030	3000 mm			
050	5000 mm			
100	10000 mm			


Item		Specifications
Cable O.D.		ø6.7 mm
Conductor nominal	Power pair	0.34 mm ² /AWG22
cross section Data pair		0.25 mm ² /AWG24
Wire O.D.	Power pair	1.4 mm
(Including insulator) Data pair		2.05 mm
Min. bending radius (Fixed)		67 mm




EX9-AC 005 DN-SAPA (With angled connector on both sides (Socket/Plug))

• Cable length (L)							
005	500 mm						
010	1000 mm						
020	2000 mm						
030	3000 mm						
050	5000 mm						
100	10000 mm						


	Specifications					
	ø6.7 mm					
Power pair	0.34 mm ² /AWG22					
Data pair	0.25 mm ² /AWG24					
Power pair	1.4 mm					
Data pair	2.05 mm					
Fixed)	67 mm					
	Data pair Power pair Data pair					



Communication Cable




Communication Cable



EX9-AC 005 EN-PAPA (With angled connector on both sides (Plug/Plug))

•Cab	•Cable length (L)							
005	500 mm							
010	1000 mm							
020	2000 mm							
030	3000 mm							
050	5000 mm							
100	10000 mm							




Min. bending radius (Fixed)

19.5 mm


Cable O.D.	ø6.5 mm
Conductor nominal cross section	0.34 mm ² /AWG22
Wire O.D. (Including insulator)	1.55 mm
Min. bending radius (Fixed)	19.5 mm

Communication Cable



(1)Communication cable

EX9-AC 005 -SSPS (With connector on both sides (Socket/Plug))




Communication Cable

For IO-Link

②Y branch connector

This connector is used to supply power to the valve manifold by branching the IO-Link communication cable in cases where a port class A IO-Link master is used. 50







*1 When used as an IO-Link communication cable *2 When used as a solenoid valve power supply cable

SMC


2 Field-wireable Communication Connector



Over Supply Cable (For SI unit)



Power Supply Cable (For SI unit/For power block)




Seal Cap (10 pcs.)

Use this on ports that are not being used for communication connector (M12 connector socket). Use of this seal cap maintains the integrity of the IP67 enclosure.


 $\ast~$ Tighten the seal cap with the prescribed tightening torque. (For M12: 0.1 N·m)




Connector specification **TS** For M12 connector socket (10 pcs.)




For M12 connector socket



Output Block



Dimensions/Parts Description



Specifications

opcome											
	Model	EX9-OET1	EX9-OET2	EX9-OEP1	EX9-OEP2						
Internal cu	rrent consumption	40 mA or less									
	Output type	Source/PNP	Sink/NPN	Source/PNP	Sink/NPN						
	Output type	(Negative common)	(Positive common)	(Negative common)	(Positive common)						
	Number of outputs	2 outputs									
Output	Power supply	Interna	l power	Integrated power supply method							
	method	supply	method	(Power block: supplied from EX9-PE1)							
	Output device supply voltage		24 \	/DC							
	Output device supply current	Max. 42 mA/po	int (1.0 W/point)	Max. 0.5 A/point (12 W/point)							
Environmental	Enclosure	IP67									
resistance	Operating temperature range		–10 to	50°C							
resistance	Operating humidity range	35 to	85% RH (N	No condensation)							
Standard	S	CE/UKCA marking, UL (CSA)									
Weight		120 g									

- Output devices other than valve manifold can be operated.
- By using the power block and output block for high watt load, operation up to 0.5 A/point can be performed.
- It is possible to mount the output block and power block additionally between the SI unit and the solenoid valve (The surplus I/O points are used).
- 2 point outputs per output block (M12 connector)

Cannot be used with PROFIsafe compatible SI unit EX260-FPS1, or the Safety over EtherCAT[®] compatible SI unit EX260-FSE1.


You are requested to connect it to an SI unit and a valve manifold. For detailed specifications, refer to the operation manual that can be downloaded from SMC website: https://www.smcworld.com

Power Block

EX9-PE1



Dimensions/Parts Description



Specifications


Mo	odel	EX9-PE1						
Connection	block	Output block for high wattage load						
Connection b	olock stations	Output block: Max. 8 stations						
Power supply for output	Power supply voltage	22.8 to 26.4 VDC						
and internal control	Internal current consumption	20 mA or less						
Supply curre	ent	Max. 3.1 A*1						
Fusing and all	Enclosure	IP67						
Environmental resistance	Operating temperature range	–10 to 50°C						
resistance	Operating humidity range	35 to 85% RH (No condensation)						
Standards		CE/UKCA marking, UL (CSA)						
Weight		120 g						
Enclosed pa	rts	Seal cap (for M12 connector) 1 pc.						

1 When using with 3.0 to 3.1 A, the ambient temperature should not exceed 40°C, and do not bundle the cable.

Refer to page 25 for the power supply cable for power block.

Connector for Output Block Wiring

Field-wireable connector for connecting an output device to an output block




Refer to page 25 for the power supply cable for power block.

9 End Plate

Use when an output block is being used and a valve manifold is not connected.

EX9-EA03




End plate

<Example of use>

Bracket Plate/DIN Rail Mounting Bracket A reinforcing brace used to mount an output block or power block onto an SI unit

A reinforcing brace used to mount an output block or power block onto an SI unit To prevent connection failure between products due to deflection, use this bracket plate whenever an output block or power block is mounted.



EX260 Series Made to Order


Please contact SMC for detailed specifications and lead times.



SI Unit

Prepare the SI unit and valve manifold (without SI unit) separately, and combine them before use.

①EtherNet/IP[™] LAN cable connectable RJ45 communication connectors



The dimensions when combined with the valve manifold are the same as the dimensions of the valve manifold with a standard EX260 series unit mounted.

②EtherNet/IP[™] Web server function compatible


EX260-SEN1-X194

- Web server compatible: Can conduct a solenoid valve operation test (ON/OFF), check communication state, set QuickConnect™, etc.
- Applicable to the power supply taken from Rockwell Automation's safe output module with pulse test function
- Compliant with QuickConnect[™] class A specifications
- The gateway address is set to 192.168. . 001 when the IP address is set by the rotary switch.
- Dimensions are the same as those of the standard type.


ss 🔊 http	p://192.1	68.0.1/																
Addres	8	192.16	8.0.1				EX2	60-5	SEN1	-X1	94 F	orce (utput	: h	ctive			
iule st	atus	16h/3	20ut De	vice Ope	rational						N	etwor}	stati	16 : No	t Establi	shed		∕⊘SM(
O Status	Pr	operties	Pe	rformane	:e	Diagnosti		infig										EDS Ma
Offset		INPUT DATA																
(INT)	15	14	13	12	11	10	9	Bi	17	6	5	4	3	2	1	0	Hex	Description
8	0	0	0	0	0	0	0	0	0	0	0	8	0	0	0	0	#0000	
Chan	ge Pass	word	1							-	-		-			-	Execute R	eset Force output
Offset			,							OUTI	UT DAT	A						
(INT)	15							Bi									Hex	Description
8	15	14	13	12	11	10	9	8	7	6	5	4	3	2	0	0	#0000	
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	#0000	
			-										-			-		

Web server screen (Example)

Communication Cable



Power Supply Cable



Connections (IO-Link) *1 V

*1 When used as an IO-Link communication cable *2 When used as a solenoid valve power supply cable



EX260 Series **Specific Product Precautions**

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For fieldbus system precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Wiring

A Caution

1. Select connectors that are ø16 or less if mounting valve manifolds directly using field-wireable connectors for SI unit power supply wiring.

Using large diameter connectors causes interference with the mounting surface.

The following cables with connectors are recommended.

For EX260-SPR /-SDN /-SEC /-SPN /-SEN /-SPL / -FPS1/-FSF1

<Cable with connector>

- EX500-AP

PCA-1401804/-1401805/-1401806

For EX260-SMJ

<Cable with connector>

- FX9-AC
- PCA-1401807/-1401808/-1401809

Operating Environment

A Caution

1. Select the proper type of enclosure according to the operating environment.

IP67 is achieved when the following conditions are met.

- 1) Provide appropriate wiring between all units using electrical wiring cables, communication connectors and cables with M12 connectors.
- 2) Appropriately mount each unit and valve manifold.
- 3) Be sure to mount a seal cap on any unused connectors.

If using in an environment that is exposed to water splashes, please take measures such as using a cover.

When the enclosure is IP40, do not use in an operating environment or atmosphere where it may come in contact with corrosive gas, chemical agents, seawater, water, or water vapor.

When connected to the EX260-SPR5/6/7/8 and EX260-SCT1. manifold enclosure is IP40.

Adjustment / Operation

A Caution

1. For details on programming and address setting, refer to the manual from the PLC manufacturer.

The programming content related to the protocol is designed by the manufacturer of the PLC used.

2. For the EX260-SPN, the side of the SI unit may become hot.

It may cause burns.

Trademark

DeviceNet[®] is a registered trademark of ODVA, Inc.

EtherNet/IP[®] is a registered trademark of ODVA, Inc.

EtherCAT® and Safety over EtherCAT® are registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.

Modbus® is a registered trademark of Schneider Electric, licensed to the Modbus Organization, Inc.

QuickConnect[™] is a trademark of ODVA.





These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of "Caution," "Warning" or "Danger." They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC)*1), and other safety regulations.

Danger : Danger indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury. Marning: Warning indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.

Caution: Caution indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.

A Warning

1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.

Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalog information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.

2. Only personnel with appropriate training should operate machinery and equipment.

The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.

- 3. Do not service or attempt to remove product and machinery/ equipment until safety is confirmed.
 - 1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
 - 2. When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
 - 3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.
- 4. SMC products cannot be used beyond their specifications. They are not developed, designed, and manufactured to be used under the following conditions or environments. Use under such conditions or environments is not allowed.
 - 1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
 - 2. Use for nuclear power, railways, aviation, space equipment, ships, vehicles, military application, equipment affecting human life, body, and property, combustion equipment, entertainment equipment, emergency shut-off circuits, press clutches, brake circuits, safety equipment, etc., and use for applications that do not conform to standard specifications such as catalogs and operation manuals.
 - 3. Use for interlock circuits, except for use with double interlock such as installing a mechanical protection function in case of failure. Please periodically inspect the product to confirm that the product is operating properly.

*1) ISO 4414: Pneumatic fluid power - General rules and safety requirements for systems and their components ISO 4413: Hydraulic fluid power - General rules and safety requirements for systems and their components IEC 60204-1: Safety of machinery - Electrical equipment of machines - Part 1: General requirements ISO 10218-1: Robots and robotic devices - Safety requirements for industrial robots - Part 1: Robots etc.

SMC develops, designs, and manufactures products to be used for automatic control equipment, and provides them for peaceful use in manufacturing industries.

Use in non-manufacturing industries is not allowed.

Products SMC manufactures and sells cannot be used for the purpose of transactions or certification specified in the Measurement Act of each country. The new Measurement Act prohibits use of any unit other than SI units in Japan.

Limited warranty and Disclaimer/ Compliance Requirements

The product used is subject to the following "Limited warranty and Disclaimer" and "Compliance Requirements".

Read and accept them before using the product.

Limited warranty and Disclaimer

- 1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered, whichever is first.*2) Also, the product may have specified durability, running distance or replacement parts. Please consult your nearest sales branch.
- 2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided. This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.
- 3. Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalog for the particular products.
 - *2) Suction cups (Vacuum pads) are excluded from this 1 year warranty. A suction cup (vacuum pad) is a consumable part, so it is warranted for a year after it is delivered.

Also, even within the warranty period, the wear of a product due to the use of the suction cup (vacuum pad) or failure due to the deterioration of rubber material are not allowed by the limited warranty.

Compliance Requirements

supported protocols

- 1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
- 2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.

Edition D * A functional safety standard compliant product has been added. * Number of pages has been increased from 28 to 32.

* Number of pages has been increased from 32 to 33.

* Added Safety over EtherCAT® and CC-Link IE TSN to the list of

Revision History

н

- Edition B * EtherNet/IP[™] has been added to applicable Fieldbus protocols.
- Edition C * The IO-Link compatible EX260-SIL1 has been added.
 - * Accessories and made-to-order specifications have been added.
 - * "How to Order Manifold" and "Dimensions" pages have been deleted.
 - * Number of pages has been decreased from 52 to 28.

A Safety Instructions Be sure to read the "Handling Precautions for SMC Products" (M-E03-3) and "Operation Manual" before use.

Edition E

SMC Corporation https://www.smcworld.com